Date : 4 April 2023

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE235000 TE243127 Rev 2 TE251144 TE259675 TE283696 TEP100108-1000 TEP101540-1001 TEP107175-1001	**CERTIFICATE NUMBER**	164q
DATE OF ISSUE	13 May 2009 09 January 2012 16 February 2012 14 October 2013 15 September 2015 06 November 2015 16 February 2016 01 August 2018	**DATE OF ISSUE**	30 July 2021
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Hochiki Europe (UK) Ltd	**NAME OF THE BRAND**	Hochiki Europe (UK) Ltd

BRE GLOBAL LTD
BUCKNALLS LAN
WATFORD
WD25 9XX, UK

FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Grosvenor Road Gillingham Business Park Gillingham Kent ME8 0SA United Kingdom	**MODEL / NO**	CHQ-SZM/OEM(SCI) CHQ-SZM/M(SCI) CHQ-SZM/DIN(SCI) CHQ-DIM/OEM(SCI) CHQ-DIM/M(SCI) CHQ-DIM/DIN(SCI) CHQ-DSC/OEM(SCI) CHQ-DSC/M(SCI) CHQ-DSC/DIN(SCI) CHQ-DRC/OEM(SCI) CHQ-DRC/M(SCI) CHQ-DRC/DIN(SCI) CHQ-DZM(SCI) CHQ-DZM/DIN(SCI) CHQ-DZM(SCI)-IS CHQ-DZM/DIN(SCI)-IS CHQ-PCM(SCI) CHQ-MRC2/DIN(SCI) CHQ-MRC2(SCI) CHQ-DIM2(SCI) CHQ-DIM2/DIN(SCI) CHQ-DRC2(SCI) CHQ-DRC2/DIN(SCI) CHQ-SZM2(SCI) CHQ-SZM2/DIN(SCI) CHQ-DSC2(SCI) CHQ-DSC2/DIN-(SCI) CHQ-MRC2/FS(SCI) CHQ-MRC2/FSDIN(SCI)
WEBSITE	www.hochikieurope.com	**LOGO ON THE PRODUCT**	HOCHIKI
TEL	+44 (0)1634 260133	**EMAIL**	info@hochikieurope.com

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report				Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	CHQ-SZM/OEM(SCI), CHQ-SZM/M(SCI),	Intelligent Analogue Addressable Single Zone Monitor with Short Circuit Isolator	164q/01	
	CHQ-SZM/DIN(SCI)	Intelligent Analogue Addressable Single Zone Monitor with Short Circuit Isolator	164q/02	
	CHQ-DIM/OEM(SCI), CHQ-DIM/M(SCI),	Intelligent Analogue Addressable Dual Input Module with Short Circuit Isolator	164q/03	
	CHQ-DIM/DIN(SCI)	Intelligent Analogue Addressable Dual Input Module with Short Circuit Isolator (DIN rail version)	164q/04	
	CHQ-DSC/OEM(SCI), CHQ-DSC/M(SCI),	Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator	164q/05	
	CHQ-DSC/DIN(SCI)	Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (DIN rail version)	164q/06	
	CHQ-DRC/OEM(SCI) CHQ-DRC/M(SCI),	Intelligent Analogue Addressable Dual Relay Controller with Short Circuit Isolator	164q/07	
	CHQ-DRC/DIN(SCI)	Intelligent Analogue Addressable Dual Relay Controller with Short Circuit Isolator (DIN rail version)	164q/08	
	CHQ-DZM(SCI),	Intelligent Analogue Addressable Dual Zone Monitor with Short Circuit Isolator	164q/09	
	CHQ-DZM/DIN(SCI)	Intelligent Analogue Addressable Dual Zone Monitor with Short Circuit Isolator (DIN rail version)	164q/10	
	CHQ-DZM(SCI)-IS,	Intelligent Analogue Addressable Intrinsically Safe Dual Zone Monitor with Short Circuit Isolator	164q/11	
	CHQ-DZM/DIN(SCI)-IS	Intelligent Analogue Addressable Intrinsically Safe Dual Zone Monitor with Short Circuit Isolator (DIN rail version)	164q/12	
	CHQ-PCM(SCI),	Analogue Addressable 4 Input, 4 Output Plant Control Module with Short Circuit Isolator Note: The device must be in an enclosure as defined in the manufacturers installation manual.	164q/13	
	CHQ-PCM/DIN(SCI)	Analogue Addressable 4 Input, 4 Output Plant Control Module with Short Circuit Isolator Note: The device must be in an enclosure as defined in the manufacturers installation manual.	164q/14	
	CHQ-MRC2/DIN(SCI)	Intelligent Analogue Addressable Mains Relay Controller with Short Circuit Isolator Note: The device must be in an enclosure as defined in the manufacturers installation manual.	164q/15	
	CHQ-MRC2(SCI),	Intelligent Analogue Addressable Mains Relay Controller with Short Circuit Isolator	164q/16	
	CHQ-DIM2(SCI),	Analogue Addressable Dual Input Module with Short Circuit Isolator	164q/19	
	CHQ-DIM2/DIN(SCI)	Analogue Addressable Dual Input Module with Short Circuit Isolator (DIN Rail Version)	164q/20	
	CHQ-DR2(SCI),	Analogue Addressable Dual Relay Controller with Short Circuit Isolator	164q/21	
	CHQ-DRC2/DIN(SCI)	Analogue Addressable Dual Relay Controller with Short Circuit Isolator (DIN Rail Version)	164q/22	
	CHQ-SZM2(SCI),	Intelligent Analogue Addressable Single Zone Monitor with Short Circuit Isolator	164q/23	
	CHQ-SZM2/DIN(SCI)	Intelligent Analogue Addressable Single Zone Monitor with Short Circuit Isolator (DIN Rail Version)	164q/24	

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	CHQ-DSC2(SCI),	Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator	164q/25	
	CHQ-DSC2/DIN-(SCI)	Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (DIN Rail Version)	164q/26	
	CHQ-MRC2/FS(SCI),	Intelligent Analogue Addressable Mains Relay Controller with Short Circuit Isolator – Fail Safe Note: The device must be in an enclosure as defined in the manufacturers installation manual.	164q/27	
	CHQ-MRC2/FSDIN(SCI)	Intelligent Analogue Addressable Mains Relay Controller with Short Circuit Isolator (DIN Rail Version) – Fail Safe Note: The device must be in an enclosure as defined in the manufacturers installation manual.	164q/28	

TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-17:2005 EN 54-18:2005	
TEST DESCRIPTION	TE235000 164q/01/02/03/04/05/06/07/08 The object of this evaluation was to examine the construction and assess the performance of the Hochiki Europe (UK) Limited., CHQ-MRC OEM (SCI), CHQ-SZM OEM (SCI), CHQ-DIM OEM (SCI), CHQ-DSC OEM (SCI) and CHQ-DRC OEM (SCI) range of modules and the HCP-W manual call point to the requirements of Lloyds Register, Test Specification Number 1: 20025 and Germanischer Lloyd/ 20034 as specified in LPCB Test Schedule E120999/2.0.	Page 5
	TE243127 Rev 2 164q/09/10/11/12 The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd. CHQ-DZM range of addressable dual-zone modules with short-circuit isolator for compliance with the requirements of selected clauses from EN 54-17:2005 and EN 54-18:2005 and LPCB/VdS Agreement Document for extended EMC requirements as specified in; LPCB Project number: E121312, LPCB Test schedule: E121312/1.3 Prior to EMC testing, 5 samples of the CHQ-DZM/DIN(SCI)-IS and 2 samples of the CHQ-DZM(SCI) had the polling software modified by the manufacturer to address concerns regarding the EMC radiated immunities testing. No retests were deemed necessary following this modification and the modified samples were only deployed for the EMC test clauses of EN 54-17:2005 and EN 54-18:2005.	Page 5
	TE251144 164q/13/14	Page 4

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd., CHQ-PCM/DIN(SCI) and CHQ-PCM(SCI) addressable, 4-input 4-output, plant control modules with short-circuit isolator for compliance with the requirements of selected clauses from EN 54-17:2005, EN 54-18:2005 and LPCB/VdS Agreement Documents for extended EMC and short-circuit isolator system test requirements as specified in LPCB Project number: E121617, LPCB Test schedule: E121617/1.0.	
	TE259675 164q/15/16 The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd. CHQ-MRC2(SCI) and CHQ-MRC2/DIN(SCI) addressable mains relay controller modules with short-circuit isolator for compliance with the requirements of selected clauses from EN 54-17:2005, EN 54-18:2005 and LPCB/VdS Agreement Documents AD2 and AD18 for extended EMC requirements as specified in LPCB Project number: E121978, LPCB Test schedule: E121978/1.1	Page 4
	TE283696 164q/19/20/21/22 The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd CHQ-DIM2 (SCI), CHQ-DRC2(SCI), CHQ-DIM2/DIN(SCI) and CHQ-DRC2/DIN(SCI), Analogue Addressable Dual Input Module and Dual Relay Controller with Short Circuit Isolator for compliance with the requirements of EN 54-18:2005 and EN 54-17:2005. The CHQ-DIM2/DIN (SCI) and CHQ-DRC2/DIN(SCI) are variants of CHQ-DIM2(SCI) and CHQ-DRC2(SCI). The only difference between DIN and non-DIN version is the installation method. The DIN models are mounted in the SMB-2 & SMB-3 enclosures (refer to Installation Instructions: 2-3-0-1731 issue 2 & 2-3-0-1730 issue 4). CHQ-DIM2(SCI) The CHQ-DIM2 is based on the same PCB design as the previously approved CHQ-PCM/DIN/OEM(SCI).The test report number for the CHQ-PCM/DIN/OEM(SCI) is: TE251144 and the project number is: E121617. The CHQ-DIM2 (SCI) incorporates two inputs (hence the name dual input module). There are modifications to the PCB in terms of component changes and PCB depopulation. All four relays have been removed from the PCB plus the removal of two of the four inputs, including all associated component networks.	Page 5

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	CHQ-DRC2(SCI) The CHQ-DRC2 is based on a depopulated version of the previously approved CHQ-PCM/DIN/OEM (SCI). The test report number for the CHQ-PCM/DIN/OEM(SCI) is: TE251144 and the project number is: E121617. The CHQ-DRC2 (SCI) has one input and two outputs (hence the name dual relay controller).	Page 4
	TEP100108-1000 164q/23/24 The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd, CHQ-SZM2 (SCI) and CHQ-SZM2/DIN (SCI) Intelligent Analogue Addressable Single Zone Monitors with Short Circuit Isolators for compliance with the requirements of EN 54-18:2005, LPCB/VdS AD EN 54-18 revision 2, EN 54-17:2005 and LPCB/VdS AD EN 54-17 revision 2. Testing has been reduced as the CHQ-SZM2 (SCI) and CHQ-SZM2/DIN (SCI) models have the same SCI circuitry that was previously tested on model CHQ-DZM (Reference project No.E121312, Test report No. TE243127). Testing was performed on what is considered to be the worst case variants, the non-DIN rail models.	Page 4
	TEP101540-1001 164q/25/26 The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd CHQ-DSC2(SCI) and CHQ-DSC2/DIN(SCI), Intelligent Analogue Addressable Dual Sounder Controllers with Short Circuit Isolators for compliance with the requirements of EN 54-18:2005 and EN54-17:2005, LPCB/VdS AD EN 54-18 Rev 2, and LPCB/VdS AD EN 54-17 Rev 2.	Page 4
	TE-P107175-1001 164q/27/28 The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd, CHQ-MRC2 range of intelligent analogue addressable mains relay controllers with short circuit isolators for compliance with the requirements of EN 54-17:2005, LPCB/VdS AD EN 54-17, EN 54-18: 2005 and LPCB/VDS AD EN 54-18.	Page 4
SPECIFICATION OF TEST SPECIMEN	TE235000 164q/01/02/03/04/05/06/07/08	Page 6

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Equipment		
No.	**Description**	**Receipt date**
10	Hochiki Europe (UK) Ltd, CHQ-MRC OEM (SCI) mains relay controller with isolators.	05/10/2007
10	Hochiki Europe (UK) Ltd, CHQ-SZM OEM (SCI) single zone monitor with isolators.	05/10/2007
10	Hochiki Europe (UK) Ltd, CHQ-DIM OEM (SCI) dual input module with isolators.	05/10/2007
10	Hochiki Europe (UK) Ltd, CHQ-DSC OEM (SCI) dual sounder controller with isolators.	05/10/2007
10	Hochiki Europe (UK) Ltd, CHQ-DRC OEM (SCI) dual relay controller with isolators.	05/10/2007
10	Hochiki Europe (UK) Ltd, HCP-W manual call points.	05/10/2007
30	Hochiki Europe (UK) Ltd, CHQ-BACKBOX.	05/10/2007
5	Hochiki Europe (UK) Ltd, HCP-W manual call points – modified samples due to the failure highlighted during Clause 16 – Electromagnetic fields test taken from Germanischer Lloyd/ 2003.	24/02/2008
1	Hochiki Europe (UK) Ltd, CHQ-DSC OEM (SCI) dual sounder controller with isolator – modified sample due to failure highlighted during Clause 19 Conducted Slow Transient (Surge) test taken from Germanischer Lloyd/ 2003.	07/05/2008

TE243127 Rev 2

164q/09/10/11/12

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Equipment submitted for testing

No.	Description	Receipt date
16	CHQ-DZM/DIN (SCI)-IS Dual-Zone Modules	7 October 2010
6	CHQ-DZM (SCI) Dual-Zone Modules	7 October 2010
5	CHQ-DZM/DIN (SCI)-IS Dual-Zone Modules (5 samples, from original delivery of 16, with modified polling software for EMC testing only)	14 January 2011
2	CHQ-DZM (SCI) Dual-Zone Modules (2 samples, from original delivery of 6, with modified polling software for EMC testing only)	14 January 2011
2	MCP1A (CCP-E-IS) intrinsically safe manual callpoints	01 March 2011
1	CHQ-BACKBOX	01 March 2011
2	CHQ-DZM/DIN (SCI)-IS Dual-Zone Modules (2 new samples with new DIP switches)	01 April 2011
1	SMB-3 Enclosure for SO2 testing of DIN module	01 April 2011

Equipment submitted for testing		
No.	**Description**	**Receipt date**
14	CHQ-PCM/DIN(SCI)	21/03/2011
5	CHQ-PCM(SCI)	21/03/2011

Second Submission

Equipment submitted for testing		
No.	**Description**	**Receipt date**
4	CHQ-PCM/DIN(SCI) with modified SCI software	30/03/2011

Page 6

TE259675

164q/15/16

Equipment submitted for testing		
No.	**Description**	**Receipt date**
14	CHQ-MRC2(SCI)	21/04/2011
5	CHQ-MRC2/DIN(SCI)	21/04/2011
1	TK-PC-1811 enclosure with cabling and cable glands	21/04/2011

Second Submission

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Equipment submitted for testing		
No.	**Description**	**Receipt date**
2	CHQ-MRC2(SCI) for shock retest	06/06/2011
2	CHQ-MRC2/DIN(SCI)	23/04/2013

Third Submission

Equipment submitted for testing		
No.	**Description**	**Receipt date**
2	CHQ-MRC2(SCI) for shock retest	01/02/2012

Fourth Submission

Equipment submitted for testing		
No.	**Description**	**Receipt date**
2	CHQ-MRC2(SCI) for impact and additional EMC testing	23/04/2013

Page 6

TE283696

164q/19/20/21/22

Equipment submitted for testing		
No.	**Description**	**Receipt date**
5	CHQ-DIM2(SCI)- Analogue addressable Dual Input Module with short circuit isolator	03/09/2014
5	CHQ-DRC2 (SCI)- Analogue addressable Dual Relay Controller with short circuit isolator	03/09/2014

Page 5

TEP100108-1000

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

164q/23/24

Equipment		
No.	**Description**	**Receipt date**
14	CHQ-SZM2 (SCI) Intelligent Analogue Addressable Single Zone Monitors with Short Circuit Isolators	13/07/2015
14	CHQ-SZM2/DIN (SCI) Intelligent Analogue Addressable Single Zone Monitors with Short Circuit Isolators	13/07/2015
1	Orian Fire panel	31/07/2015
1	Kentec Electronics Series 8000	13/07/2015
2	SMB-3 Enclosures	31/07/2015
2	ALN-EN Analogue addressable smoke detectors	31/07/2015
1	SLR-E3N Conventional smoke detector	31/07/2015
1	Hochiki laptop and PC-DCI simulator	17/07/2015

Page 5

TEP101540-1001

164q/25/26

Equipment submitted for testing		
No.	**Description**	**Receipt date**
8	CHQ-DSC2(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator	6/10/15
14	CHQ-DSC2/DIN(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (DIN rail version)	6/10/15
1	Kentec Series 8000 Fire Alarm Control Panel	Previously provided

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Second Submission

Equipment submitted for testing		
No.	**Description**	**Receipt date**
8	CHQ-DSC2(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator	31/11/15
14	CHQ-DSC2/DIN(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (DIN rail version)	31/11/15
1	Kentec Series 8000 Fire Alarm Control Panel	Previously provided

TE-P107175-1001

164q/27/28

Equipment		
Quantity	**Description**	**Receipt date**
8	Hochiki Europe (UK) Ltd CHQ-MRC2/FS (SCI) relay controller with short circuit isolator.	23/10/2017

Page 6

TEST RESULT
(SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)

TE235000

164q/01/02/03/04/05/06/07/08

The Hochiki Europe (UK) Limited., CHQ-MRC OEM (SCI), CHQ-SZM OEM (SCI), CHQ-DIM OEM (SCI) and CHQ-DRC OEM (SCI) range of modules met the requirements of a series of tests taken from Lloyds Register, Test Specification Number 1: 20025 and Germanischer Lloyd/ 20034 as specified in LPCB Test Schedule E120999/2.0 on the first submission.

The CHQ-DSC OEM (SCI) and the HCP-W manual call point met the requirements of a series of tests taken from Lloyds Register, Test Specification Number 1: 20025 and Germanischer Lloyd/ 20034 as specified in LPCB Test Schedule E120999/2.0 on the first submission with the exception of Clause 19 Conducted Slow Transients test taken from Germanischer Lloyd/ 20034 for CHQ-DSC OEM (SCI) module (refer to Section 6.47) and Clause 16 Electromagnetic Fields test taken from Germanischer Lloyd/ 20034 for the HCP-W manual call point (refer to Section 6.31).

Page 143

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	Following a series of modifications made by the manufacturer the requirements of the above Clauses were subsequently met on the second submission.	Page 49
	TE243127 Rev 2 164q/09/10/11/12 The Hochiki Europe (UK) Ltd. CHQ-DZM range of addressable dual zone modules with short-circuit isolator met the requirements of tests specified in LPCB Test Schedule E121312/1.3 taken from EN 54-17:2005 and EN 54-18:2005 and LPCB/VdS Agreement Document for extended EMC requirements on the first submission.	Page 31
	TE251144 164q/13/14 The Hochiki Europe (UK) Ltd. CHQ-PCM/DIN(SCI) and CHQ-PCM(SCI) addressable, 4-input 4-output, plant control modules with short-circuit isolator met the requirements of tests specified in LPCB Test Schedule E121617/1.0 taken from EN 54-18:2005 on the first submission and EN 54-17:2005 on the first submission with the exception of the system test requirement as defined in the LPCB/VdS agreement document which was met on the second submission.	Page 35
	TE259675 164q/15/16 The Hochiki Europe (UK) Ltd. CHQ-MRC2(SCI) addressable mains relay controller module with short-circuit isolator met the requirements of tests specified in LPCB Test Schedule E121978/1.1 taken from EN 54-18:2005 on the first submission and EN 54-17:2005 on the first submission with the exception of EN 54-18:2005 Clause 5.8 which was met on the third submission. A subsequent change of mains relay type for an improved specification relay and a change of style of backplate to an adaptor plate style resulted in a fourth submission. Additional EMC testing relating to the relay modification was also required and successfully performed at this fourth submission. The Hochiki Europe (UK) Ltd. CHQ-MRC2/DIN(SCI) addressable mains relay controller module with short-circuit isolator met the requirements of tests specified in LPCB Test Schedule E121978/1.1 taken from EN 54-18:2005 on the first submission and EN 54-17:2005 on the first submission with the exception of EN 54-18:2005, Clause 5.8 which became not applicable on the second submission.	Page 44

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	TE283696 164q/19/20/21/22 1 The Analogue addressable Dual Input Modules and Dual Relay Controller with short circuit isolator, models: CHQ-DIM2 (SCI), CHQ-DRC2 (SCI), CHQ-DIM2/DIN (SCI) and CHQ-DRC2/DIN (SCI) met the requirements of tests specified in LPCB Test Schedule E122768/1.2 taken from EN 54-18:2005 and EN 54-17:2005 on the first submission	Page 21
	TEP100108-1000 164q/23/24 The Hochiki Europe (UK) Ltd, CHQ-SZM2 (SCI) and CHQ-SZM2/DIN (SCI) Intelligent Analogue Addressable Single Zone Monitors with Short Circuit Isolators both met the requirements of tests specified in LPCB Test Schedule P100108/1.2 taken from EN 54-18:2005, LPCB/VdS AD EN 54-18 revision 2, EN 54-17:2005 as well as LPCB/VdS AD EN 54-17 revision 2 on the first submission.	
	TEP101540-1001 164q/25/26 The Hochiki Europe (UK) Ltd CHQ-DSC2(SCI) and CHQ-DSC2/DIN(SCI) Intelligent Analogue Addressable Dual Sounder Controllers with Short Circuit Isolators met the requirements of tests specified in LPCB Test Schedule P101540/1.2 taken from EN 54-18:2005 and EN-54-17:2005, LPCB/VdS AD EN 54-18 Rev 2 and LPCB/VdS AD EN 54-17 Rev 2 on the second submission.	Page 37
	TE-P107175-1001 164q/27/28 The Hochiki Europe (UK) Ltd CHQ-MRC2 range of intelligent analogue addressable mains relay controllers with short circuit isolators met the requirements of tests specified in Test Schedule P107175/1.1 taken from EN 54-17:2005 and EN 54-18: 2005, LPCB/VDS AD EN 54-18 and LPCB/VdS AD EN 54-17 on the first submission.	

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC. BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	164q/01/02/03/04/05	CHQ-SZM/OEM(SCI)	2-3-0-778		
	164q/06/07/08	CHQ-DSC/DIN(SCI)	2-3-0-780		
	164q/09/10	CHQ-DZM(SCI)	2-3-0-778		
	164q/11/12	CHQ-DZM(SCI)-IS	2-3-0-1366		
	164q/13/14	CHQ-PCM(SCI)	2-3-0-1156		
	164q/15/16	CHQ-MRC2/DIN(SCI)	2-3-0-1730		
	164q/19/20/21/22	CHQ-DIM2(SCI)	2-3-0-1731		
	164q/23/24	CHQ-SZM2(SCI)	2-3-001731		
	164q/25/26	CHQ-DSC2(SCI)	2-3-0-1730		
	164q/27/28	CHQ-MRC2/FS(SCI)	2-3-0-1730		

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	**WEBSITE**	www.breglobal.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	**EMAIL**	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX, UK		

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Shane Bartlett	**SIGNATURE**	
EMAIL / TEL	sbartlett@hochikieurope.com / 01634 266543	**FACTORY OFFICIAL SEAL**	HOCHIKI EUROPE (U.K.) LIMITED Grosvenor Road, Gillingham Business Park Gillingham, Kent ME8 0SA England
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	P Halligan BRE Global Ltd.	**SIGNATURE**	
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	**CERTIFICATION BODY OFFICIAL SEAL**	BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- **COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)**