Date : 4 April 2023

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE250066 TE286983 TE-P118399-1001	**CERTIFICATE NUMBER**	164r
DATE OF ISSUE	14 August 2009 15 January 2015 8 September 2021	**DATE OF ISSUE**	27 March 2019
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Honeywell Life Safety Romania S.R.L	**NAME OF THE BRAND**	Hochiki Europe (UK) Ltd
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Strade Salcâmilor 2 bis Lugoj Timis 305500 Romania	**MODEL / NO**	**Manual Call Points** HCP-E(SCI) HCP-W(SCI) HCP-E(DPS)-SCI HCP-W(DPS)-SCI
WEBSITE	www.hochikieurope.com	**LOGO ON THE PRODUCT**	HOCHIKI
TEL	+44 (0)1634 260133	**EMAIL**	info@hochikieurope.com

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)		

HCP-E(SCI)	Intelligent Analogue Addressable Manual Call Point with Short Circuit Isolator (SR Mounting Box)	164r/01
HCP-W(SCI)	Weatherproof Intelligent Analogue Addressable Manual Call Point with Short Circuit Isolator	164r/02
HCP-E(DPS)-SCI	Type A Indoor Dual Pole Switching Intelligent Addressable Call Point with Short Circuit Isolator (SR-1T Mounting Box)	164r/03
HCP-W(DPS)-SCI	Type A Outdoor Dual Pole Switching Intelligent Addressable Weatherproof Call Point with Short Circuit Isolator	164r/04

Ancillaries

SR Surface mounting plastic ox – Indoor models only
SR-1T Surface mounting box with cable screen terminal

CoC has been updated due to manufacturing location change from KAC Alarm Company Limited, KAC House, Thornhill Road, North Moons Moat, Redditch, B98 9ND, United Kingdom (TE250066 & TE286983) to Honeywell Life Safety Romania S.R.L., Strade Salcâmilor 2 bis, Lugoj, Timis, 305500, Romania under TE-P118399-1001.

TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-11:2001 + A1:2005 EN 54-17:2005	
TEST DESCRIPTION	TE250066 - 164r/01/02 The object of this evaluation was to examine the construction and assess the performance of the HOCHIKI Europe (UK) Ltd HCP-E(SCI) indoor and HCP-W(SCI) outdoor analogue addressable Type A re-settable manual call points incorporating short circuit isolators to a series of tests taken from EN 54-11: 20011, EN 54-17: 20052	Page 5

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	TE286983 - 164r/03/04 The object of this evaluation was to assess the performance of the HCP-E(DPS)-SCI, type A indoor, dual pole switching, intelligent, addressable manual call point and the HCP-W(DPS)-SCI type A outdoor, dual pole switching, intelligent, weatherproof addressable manual call point, both with internal short circuit isolation, for compliance with the requirements of selected clauses taken from to EN 54-11:2001+A1:2005 and EN 54-17:2005 as detailed in LPCB Test Schedule Number E122883/1.1.	Page 4
	TE-P118399-1001 The object of this evaluation was to assess the performance of the KAC Alarm Company Ltd., ZP785-3 addressable Type A manual call point, MCP5A-RP and MCP820 addressable Type A manual call points with short circuit isolators for compliance with the requirements of selected Clauses taken from EN 54-11:2001 and EN 54-17:2005. *(The above products have product similarities to the following HCP-E(SCI), HCP-E(DPS)-SCI, HCP-W(SCI) and HCP-W(DPS)-SCI. The results of TE-P118399-1001 can be transferred to the Hochiki Europe (UK) Ltd products.)*	Page 4
SPECIFICATION OF TEST SPECIMEN	TE250066 - 164r/01/02	Page 6

Equipment submitted for testing

No.	Description	Receipt date
14	HOCHIKI analogue addressable HCP-W(SCI) Type A outdoor re-settable manual call points with surface mounting back box.	28/05/2009
1	HOCHIKI analogue addressable HCP-E(SCI) Type A indoor re-settable manual call point.	28/05/2009

	TE286983 - 164r/03/04	Page 5

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Equipment submitted for testing

No.	Description	Receipt date
5	HCP-E(DPS)-SCI, type A, indoor dual pole switching, intelligent, addressable call points	19/05/2014
5	HCP-W(DPS)-SCI type A outdoor, dual pole switching, intelligent, weatherproof addressable call point	19/05/2014

TEST RESULT
(SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)

TE250066 - 164r/01/02 — Page 54

The HOCHIKI Europe analogue addressable HCP E(SCI) Type A Indoor re-settable manual call point with short circuit isolator and the analogue addressable HCP W(SCI) Type A outdoor re-settable manual call point with short circuit isolator met the requirements of a series of tests taken from EN 54-11: 20011, EN 54- 17: 20052 as specified in LPCB Test Schedule E121569/1.0 on the first submission

TE286983 - 164r/03/04 — Page 18

The Hochiki Europe (UK) Ltd, HCP-E(DPS)-SCI type A indoor, dual pole switching, intelligent, addressable manual call point and the HCP-W(DPS)-SCI type A outdoor, dual pole switching, intelligent, weatherproof addressable manual call point, both with internal short circuit isolators, were subjected to a reduced program of tests as specified in LPCB Test Schedule E122883/1.1 to the requirements of EN 54-11:2001+A1:2005 and EN 54-17:2005. All specified clauses were met on the first submission.

PRODUCT APPLICATION GUIDELINE (END USE)
(CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC.

164r/01 HCP-E(SCI) 2-3-0-635
164r/02 HCP-W(SCI) 2-3-0-750
164r/03 HCP-E(DPS)-SCI 2-3-0-635
164r/04 HCP-W(DPS)-SCI 2-3-0-750

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	**WEBSITE**	www.breglobal.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	**EMAIL**	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK		

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Shane Bartlett	**SIGNATURE**	
EMAIL / TEL	sbartlett@hochikieurope.com / 01634 266543	**FACTORY OFFICIAL SEAL**	HOCHIKI EUROPE (U.K.) LIMITED Grosvenor Road, Gillingham Business Park Gillingham, Kent ME8 0SA England
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	P Halligan BRE Global Ltd.	**SIGNATURE**	
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	**CERTIFICATION BODY OFFICIAL SEAL**	BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX, UK
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- **COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)**