Date : 6 April 2023

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE-P105185-1001	**CERTIFICATE NUMBER**	164y
DATE OF ISSUE	25 January 2017	**DATE OF ISSUE**	29 September 2022
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Hochiki Europe (UK) Ltd	**NAME OF THE BRAND**	Hochiki Europe (UK) Ltd
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Grosvenor Road Gillingham Business Park Gillingham Kent ME8 0SA United Kingdom	**MODEL / NO**	**Heat Detectors** ATJ-E(WHT) ATJ-EN ATJ-EN(WHT)
WEBSITE	www.hochikieurope.com	**LOGO ON THE PRODUCT**	HOCHIKI
TEL	+44 (0)1634 260133	**EMAIL**	info@hochikieurope.com

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	ATJ-E(WHT) — Intelligent Analogue Addressable Class P Heat Detector (YBN-R/3, YBN-R/3(SCI), YBO-BS, YBO-BSB2/WL, YBO-BSB2(WHT)/WL, YBO-BSB2/RL and YBO-BSB2(WHT)/RL bases) Note: Classes A1R, BR, CR, A1S, BS and CS. — 164y/01 ATJ-EN — Intelligent Analogue Addressable Class P Heat Detector (YBN-R/3, YBO-BS, YBO-BSB2/WL, YBO-BSB2(WHT)/WL, YBO-BSB2/RL and YBO-BSB2(WHT)/RL bases) Note: Classes A1R, BR CR, A1S, BS and CS. — 164y/02 ATJ-EN(WHT) — Intelligent Analogue Addressable Class P Heat Detector (YBN-R/3, YBO-BS YBO-BSB2/WL, YBO-BSB2(WHT)/WL, YBO-BSB2/RL and YBO-BSB2(WHT)/RL bases) Note: Classes A1R, BR, CR, A1S, BS and CS. — 164y/02 **Bases** YBN-R/3 — Addressable detector base YBO-BS — Base sounder YBN-R/3(SCI) — Short circuit isolator base YBO-BSB2/WL — Base Sounder Beacon (White LED) YBO-BSB2(WHT)/WL — Base Sounder Beacon (White LED) YBO-BSB2/RL — Base Sounder Beacon (Red LED) YBO-BSB2(WHT)/RL — Base Sounder Beacon (Red LED)	N/A
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-5:2000 + A1:2002 – Test Report EN 54-5:2017 + A1:2018 Certificate standard has been updated but no further testing was required.	Page 5
TEST DESCRIPTION	The object of this evaluation was to assess the performance of the Hochiki Europe UK, models ACC-E (WHT), ACC-EN (WHT), ACC-EN,ATJ-E(WHT), ATJ-EN(WHT), ATJ-EN intelligent Analogue Addressable Multi-criteria detector and Class P Heat detectors for compliance with the requirements of a reduced series of test from EN 54-5:2000 + A1:2002 , EN 54-7:2000 + A1:2002 + A2:2006 and LPCB/VdS AD EN 54-7 , LPCB/VdS AD EN 54-5 and CEA 4021:2003-07 when used with YBN-R/3 Base.	Page 5
SPECIFICATION OF TEST SPECIMEN	Equipment No. — Description — Receipt date 20 — Hochiki ACC-EN Analogue Multi Sensor — 17/10/2016 20 — Hochiki ACC-E (WHT) Intelligent Multi-sensor — 19/10/2016 16 — ATJ-EN Intelligent Heat Sensor — 19/10/2016 16 — ATJ-E Intelligent Heat Detector — 20/10/2016 10 — YBN-R/3 Sensor Base — 19/10/2016	Page 6

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

TEST RESULT (SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	The Hochiki Europe (UK) Ltd. Intelligent Analogue Addressable Multi-criteria detector and Class P Heat detector met the requirements of tests specified in Test Schedule P105185/1.3 taken from EN 54-5:2000, EN54-7:2000, VdS AD EN 54-7, VdS AD EN 54-5 and CEA 4021:2003-07 on the first submission.	Page 58
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC. BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	**2-3-0-246 – Installation Instructions** Hochiki range of products are designed specifically for installation within industrial or commercial applications. To operate products, they will require use of approved and appropriately supported control indicating equipment (control panel). Any installation must be completed in accordance with approval, technical & local authority requirements. Deviation from any such requirements is not approved by Hochiki. Hochiki recommends installation by appropriately qualified, skilled or experienced individuals only.	N/A

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	**WEBSITE**	www.breglobal.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	**EMAIL**	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB		

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Shane Bartlett	**SIGNATURE**	
EMAIL / TEL	sbartlett@hochikieurope.com / 01634 266543	**FACTORY OFFICIAL SEAL**	HOCHIKI EUROPE (U.K.) LIMITED Grosvenor Road, Gillingham Business Park Gillingham, Kent ME8 0SA England
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd. P Halligan	**SIGNATURE**	
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	**CERTIFICATION BODY OFFICIAL SEAL**	BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- **COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)**