Date : 30 January 2024

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE214876 TE-P118399-1001	**CERTIFICATE NUMBER**	567av-(cl-5)
DATE OF ISSUE	25 June 2004 8 September 2021	**DATE OF ISSUE**	29 January 2024
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Honeywell Life Safety Romania S.R.L	**NAME OF THE BRAND**	Hochiki Europe (UK) Limited
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Strada Salcâmilor 2 bis Lugoj Timis 305500 Romania	**MODEL / NO**	CCP-E CCP-W
WEBSITE	www.hls-romania.com	**LOGO ON THE PRODUCT**	HOCHIKI
TEL	+ 40 256 350 000	**EMAIL**	info@hochikieurope.com

BTF GLOBAL LTD
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Core products are MCP1A-Rxxxxx-yyy-zz & WCP1A-Rxxxxx-yyy-zz CCP-E — Indoor Surface/Flush Mounting Conventional Manual Call Point — 567av/01 CCP-W — Outdoor Surface Mounting Conventional Manual Call Point — 567av/09	
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-11:2001 +A1: 2005	
TEST DESCRIPTION	**TE214876** The object of this evaluation was to examine the construction and assess the performance of the KAC 1, 2, 3, 4 & 7 Series Conventional Manual Call Points and 5 Series Addressable Manual Call Points for compliance with the requirements of EN 54: Part 11: 20011. GEI 1-052 – 11.06.97, Draft 2.02 and LPCB/VdS Agreement Document AD7.13.	Page 5
	TE-P118399-1001 The object of this evaluation was to assess the performance of the KAC Alarm Company Ltd., ZP785-3 addressable Type A manual call point, MCP5A-RP and MCP820 addressable Type A manual call points with short circuit isolators for compliance with the requirements of selected Clauses taken from EN 54-11:2001 and EN 54-17:2005.	Page 4
SPECIFICATION OF TEST SPECIMEN	**TE214876**	Page 6

Equipment			
No.	**Description**	**Model**	**Receipt date**
1	Conventional manual call point	MCP1A-Rxxxxx	11/11/03

TE-P118399-1001		Page 6

Equipment submitted for testing		
No.	**Description**	**Receipt date**
14	MCP5A-RP Indoor surface/flush mounting addressable call point with short circuit isolator.	18/05/2021

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

TE214876 — Page 13

EN 54-11: 2001 Clause – Title/Test	1st submission	
	Specimen No.	Pass/ Fail
4.2.1 – Marking	1	Pass
4.2.2 – Data	-	Pass
4.3 – Frangible element	1	Pass
4.7 – Construction and design	1	Pass

TEST RESULT
(SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)

The KAC Model MCP1A-Rxxxxx Indoor/Outdoor surface/flush mounting conventional manual call point met the requirements of Clauses 4.2.1, 4.2.2, 4.3 and 4.7 as specified in EN 54-11: 20011. — Page 56

TE-P118399-1001 — Page 12

EN 54-11:2001 Clause – Title/Test	Comments	Result
4.2.1 – Marking	See Section 6.1 of this test report	Pass
4.2.2 – Data	See Section 6.2 of this test report	Pass
5.2 – Operational performance	See Section 6.3 of this test report	Pass

The KAC Alarm Company Ltd., ZP785-3 addressable Type A manual call point, MCP5A-RP and MCP820 addressable Type A manual call points with short circuit isolators met the requirements of tests specified in Test Schedule P118399/1.2 taken from EN 54-11:2001 and EN 54-17:2005 on the first submission. — Page 32

PRODUCT APPLICATION GUIDELINE (END USE)
(CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC.

CCP-E
Conventional manual call point for use in fire detection and fire alarm systems for installation indoors. Refer to installation guide I56-4376-000.

CCP-W
Conventional manual call point for use in fire detection and fire alarm systems. IP67 rated for outdoor installation. Refer to installation guide I56-4380-000.

BRE GLOBAL LTD
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Watford WD25 9XX United Kingdom
WEBSITE	https://www.bregroup.com	**WEBSITE**	https://www.bregroup.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	Enquiries@bregroup.com	**EMAIL**	Enquiries@bregroup.com
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2017
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB	BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Jim Clarke	SIGNATURE	
EMAIL / TEL	Jim.clarke@honeywell.com +44 1403 226235	FACTORY OFFICIAL SEAL	SC HONEYWELL LIFE SAFETY ROMÂNIA SRL Lugoj, str. Salcâmilor nr. 2 bis, 305500, jud. Timiș, România
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd.	SIGNATURE	
EMAIL / TEL	Enquiries@bregroup.com +44 (0)333 321 88 11	CERTIFICATION BODY OFFICIAL SEAL	BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- **COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)**