Date : 03 March 2017

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE240097—2 Rev 2 TE240097-RF/1	**CERTIFICATE NUMBER**	928m-(cl-7)
DATE OF ISSUE	21 February 2011 16 February 2011	**DATE OF ISSUE**	06 March 2015
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Argus Security Srl	**NAME OF THE BRAND**	Hochiki Europe (UK) Ltd
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Via del Canneto 14 Valle delle Noghere 34015 Muggia Trieste Italy	**MODEL / NO**	Wireless Multi Criteria Detector RMD-E
WEBSITE	www.hochikieurope.com	**LOGO ON THE PRODUCT**	Hochiki
TEL	+44 (0)1634 260133	**EMAIL**	info@hochikieurope.com

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	SG200 928m/01 Hochiki Brand Name: RMD-E Wireless Multi Criteria Detector (RSM-WDB base) RSM-WDB Wireless Adaptor base	
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-5:2000 + A1:2002 EN 54-7:2000 + A1:2002 + A2:2006 EN 54-25:2008 CEA 4021: 2003	
TEST DESCRIPTION	TE240097—2 Rev 2 The object of this evaluation was to examine the construction and assess the performance of the Argus Security S.r.l. SG200 Wireless analogue addressable Class A1 Photo - thermal detector to a series of tests taken from EN 54-5:20001, EN 54-7: 20002, LPCB/VdS Agreement Document AD3.33, LPCB/VdS Agreement Document AD1.34 and CEA 4021:20035 as specified in LPCB Test Schedule E121185/2.2. Another LPCB report TE240097-RF/17 covers testing to EN54-25:20088. TE240097-RF/1 Page 5 The object of this evaluation was to assess the performance of the Argus Security S.r.l products listed below, for compliance with the requirements of tests defined in EN 54-251 and LPCB/VdS Agreement Document AD3.32, as described in Section 7 of this report.	
SPECIFICATION OF TEST SPECIMEN	TE240097—2 Rev 2 First Submission **Equipment** **No.** / **Description** / **Receipt date** 20 / Argus Security S.r.l. SG200 Wireless analogue addressable Class A1 Photo thermal detectors. / 12/5/2010 Second Submission	

BRE GLOBAL LTD
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Equipment		
No.	**Description**	**Receipt date**
20	Argus Security S.r.l. SG200 Wireless analogue addressable Class A1 Photo thermal detectors with alternative resistor value.	2/9/2010

Third Submission

Equipment		
No.	**Description**	**Receipt date**
20	Argus Security S.r.l. SG200 Wireless analogue addressable Class A1 Photo thermal detectors with modified software.	16/9/2010

Fourth Submission

Equipment		
No.	**Description**	**Receipt date**
2	Argus Security S.r.l. SG200 Wireless analogue addressable Class A1 Photo thermal detectors (additional samples were supplied to assess the requirements of Clause 4.3.1 of LPCB/VdS Agreement Document AD1.3[4] and AD3.3[3]. The Firmware version was changed from SGxxx_V7_2010_04_23.HEX to SGxxx_V714_2010_10_20.HEX).	25/10/2010

TE240097-RF/1 Page 7

Equipment		
No.	**Description**	**Receipt date**
16	SG100 Addressable wireless photoelectric smoke detector	12/5/10
8	SG200 Addressable wireless multi-sensor detector	12/5/10

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	8	SG350 Addressable wireless heat detector	12/5/10
	32	WAB100 Mounting base	12/5/10

TEST RESULT (SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	TE240097—2 Rev 2 The Argus Security S.r.l. SG200 Wireless analogue addressable Class A1 Photo thermal detector met the requirements of a series of tests taken from EN 54-5:20001, EN 54-7:20002, LPCB/VdS Agreement Document AD3.33, LPCB/VdS Agreement Document AD1.34 and CEA 4021:2003-075 as specified in LPCB Test Schedule E121185/2.2 with the exception of Clause 4.3.1 of LPCB/VdS Agreement document AD3.33 and LPCB/VdS Agreement Document AD1.34 on the first and third submissions. The requirements of Clause 4.3.1 of LPCB/VdS Agreement Document AD3.33 and Clause 4.3.1 of LPCB/VdS Agreement Document AD1.34 were met on the fourth submission. TE240097-RF/1 The Argus Security S.r.l products listed below, met the requirements of the applicable tests defined in EN 54-251 and LPCB/VdS Agreement Document AD3.32 in accordance with the relevant LPCB Test Schedules E121185/1.23, E121185/2.24 or E121185/3.25, as detailed in Section 7 of this report.	
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC.	**RMD-E L20-SG200-7000** BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	**WEBSITE**	www.breglobal.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	**EMAIL**	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK		928m-(cl-7)

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	B V Thompson	**SIGNATURE**	
EMAIL / TEL	info@argussecurity.it	**FACTORY OFFICIAL SEAL**	ARGUS SECURITY Authorised by B V Thompson on behalf of Argus Security Srl
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd. M McCullagh	**SIGNATURE**	
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	**CERTIFICATION BODY OFFICIAL SEAL**	BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.
NOTES: I Undertake that all data and information provided are genuine and accurate 928m-(cl-7)			

ATTACHMENTS:

- **COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)**