Date : 03 March 2017

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE265815 TE265815-RF/1	**CERTIFICATE NUMBER**	928p-(cl-6)
DATE OF ISSUE	14 February 2012 28 September 2012	**DATE OF ISSUE**	23 February 2012
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Argus Security Srl	**NAME OF THE BRAND**	Hochiki Europe (UK) Ltd
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Via del Canneto 14 Valle delle Noghere 34015 Muggia Trieste Italy	**MODEL / NO**	Manual Call Point RSM-CP
WEBSITE	www.hochikieurope.com	**LOGO ON THE PRODUCT**	Hochiki
TEL	+44 (0)1634 260133	**EMAIL**	info@hochikieurope.com

BRE GLOBAL LTD
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	SGCP100 928p/01 Hochiki brand name: RSM-CP Wireless Type A Resettable Indoor Manual Call Point (SR01 Surface Mount Back Box)	
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-11:2001 + A1:2005 EN 54-25:2008	
TEST DESCRIPTION	TE265815 928p/01 The object of this evaluation was to examine the construction and access the performance of the Argus Security S.r.l. model SGCP100 and SGCP100–FR wireless resettable indoor manual call points to EN 54-11: 20011. LPCB Test schedule E122163/1.12 covers testing to both EN54-11:20011 and EN54-25:20084 and additional testing taken from LPCB/VdS Agreement Document AD7.2:2010-11-066 for manual call points. The test results for EN54-25:2008 can be found in LPCB report TE265815-RF/1 TE265815-RF/1 Page 5 The object of this evaluation was to assess the performance of the Argus Security S.r.l. listed below for compliance with the requirements of the tests defined in EN 54-25[1] and LPCB/VDS Agreement document AD7.2[2] as described in Section 7 of this Report.	
SPECIFICATION OF TEST SPECIMEN	TE265815 928p/01 First Submission **Equipment** No. 16 — Description: Model SGCP100 wireless resettable indoor manual call point. — Receipt date: 7 December 2010	

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Second Submission

Equipment		
No.	**Description**	**Receipt date**
2	Model SGCP100 wireless resettable indoor manual call point modified to include a battery retaining foam insert.	7 April 2011

Third Submission

Equipment		
No.	**Description**	**Receipt date**
2	Model SGCP100 wireless resettable indoor manual call point modified to include a retaining screw to secure the front face of the call point.	17 May 2011

Fourth Submission

Equipment		
No.	**Description**	**Receipt date**
2	Model SGCP100 wireless resettable indoor manual call point modified to include an alternative tamper switch and battery protection covers.	20 September 2011
2	Model SGCP100 wireless resettable indoor manual call point with modified plated battery terminal connections.	5 December 2011

TE265815-RF/1 Page 6

Equipment		
No.	**Description**	**Receipt date**
16	Model SGCP100 wireless resettable indoor manual call point.	7 December 2010

BRE GLOBAL LTD
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

TEST RESULT **(SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)**	TE265815 928p/01 The Argus Security S.r.l. model SGCP100 wireless resettable manual call point met the requirements of a series of tests taken from EN 54-11:20011 as specified in LPCB Test Schedule E122163/1.12 on the first submission with the exception of Clause 5.1.4 Shock (operational) which met the requirements of on the third submission and Clause 5.13 SO2 corrosion (endurance) which was met on the fourth submission. The model SGCP100-FR wireless resettable manual call point met the requirements of a series of tests taken from EN 54-11:20011 as specified in LPCB Test Schedule E122163/1.12 on the first submission. TE265815-RF/1 The Argus Security S.r.l. product(s) listed below, met the requirements of the applicable tests defined in EN 54-25[1] and LPCB/VDS Agreement document AD7.2[2] in accordance with LPCBT Test Schedule E122163/1.1[3] as detailed in Section 7 of this report.	
PRODUCT APPLICATION GUIDELINE (END USE) **(CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC.**	**RMD-CP L20-SGCPX-7000** BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	**WEBSITE**	www.breglobal.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	**EMAIL**	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK		928p-(cl-6)

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	B V Thompson	**SIGNATURE**	
EMAIL / TEL	info@argussecurity.it	**FACTORY OFFICIAL SEAL**	ARGUS SECURITY Authorised by B V Thompson on behalf of Argus Security Srl
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd. M McCullagh	**SIGNATURE**	
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	**CERTIFICATION BODY OFFICIAL SEAL**	BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.
NOTES: I Undertake that all data and information provided are genuine and accurate 928p-(cl-6)			

ATTACHMENTS:

- **COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)**