Date : 03 March 2017

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE264218 TE264218-RF	**CERTIFICATE NUMBER**	928q-(cl-6)
DATE OF ISSUE	03 January 2012 20 January 2012	**DATE OF ISSUE**	31 January 2012
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Argus Security Srl	**NAME OF THE BRAND**	Hochiki Europe (UK) Ltd
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Via del Canneto 14 Valle delle Noghere 34015 Muggia Trieste Italy	**MODEL / NO**	Alarm Warning Devices RSM-BS RSM-BSB RSM-WS (RED) RSM-WSB (RED) RSM-WS (WHT) RSM-WSB (WHT)
WEBSITE	www.hochikieurope.com	**LOGO ON THE PRODUCT**	Hochiki
TEL	+44 (0)1634 260133	**EMAIL**	info@hochikieurope.com

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)		

	Argus Security Srl	Hochiki Brand
928q/01	SGRBS100	RSM-BS
	Wireless type A sounder base	
928q/02	SGRBS100-AV	RSM-BSB
	Wireless type A audiovisual sounder base	
928q/03	SGRS100	RSM-WS (RED)
	Wireless type A wall sounder	
928q/04	SGRS100-AV	RSM-WSB (RED)
	Wireless type A audiovisual wall sounder	
928q/06	SGRS100/W	RSM-WS (WHT)
	Wireless type A wall sounder – white colour	
928q/07	SGRS100-AV/W	RSM-WSB (WHT)
	Wireless type A audiovisual wall sounder– white colour	

Detectors:
ROD-E Wireless optical smoke detector
RMD-E Wireless multi-criteria detector
RHD-E Wireless heat detector

TEST STANDARD (SUCH AS ASTM/BS.EN/.DN.ETC)	EN 54-3:2001 + A1:2002 + A2:2006 EN 54-25:2008	
TEST DESCRIPTION	TE264218 Page 6 928q01/02/03/04/06/07 The object of this evaluation was to examine the construction and assess the performance of the Argus Security S.r.l. wireless wall sounders, wireless sounder bases, wireless audiovisual wall sounders and wireless audiovisual bases for compliance with the requirements of EN 54-3:20011. LPCB Test schedule E122099/1.26 covers testing to both EN54-3:20051 and EN54-25:20087 and additional testing taken from EN54-5:20055 and LPCB/VdS Agreement Document AD6.2:2010-11-064 for sounders. The test results for EN54-25:20087 can be found in LPCB report TE264218-RF/18.	

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

TE264218-RF Page 6

The object of this evaluation was to assess the performance of the Argus Security S.r.l. products listed below, for compliance with the requirements of tests defined in EN 54-25[1] and LPCB/VDS Agreement Document AD6.2[2], as described in Section 7 of this report.

SPECIFICATION OF TEST SPECIMEN

TE264218 Page 7
928q01/02/03/04/06/07
First Submission

Equipment		
No.	**Description**	**Receipt date**
14	SGRS100-AV audiovisual wireless wall sounder beacons	15 December 2010
8	SGRS100 wireless wall sounders	15 December 2010
8	SGRS100/H wireless wall sounders	15 December 2010
14	SGRBS100-AV audiovisual wireless base sounder beacons	7 December 2010
8	SGRBS100 wireless base sounder	7 December 2010

Second Submission

Equipment		
No.	**Description**	**Receipt date**
4	SGRBS100-AV modified audiovisual wireless base sounder beacons submitted to retest clauses 5.9 and 5.16b).	8 August 2011
4	SGRBS100 modified audiovisual wireless base sounders submitted to retest clause 5.16b).	8 August 2011
2	SGRBS100-AV modified audiovisual wireless bases submitted to retest clause 4.5.4.	8 August 2011

Third Submission

Equipment

BFE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

No.	Description	Receipt date
1	SGRBS100-AV audiovisual wireless base modified to include a retaining screw submitted to retest clause 4.5.4	14 September 2011
*8	SGRBS100-AV audiovisual wireless base sounder beacons supplied to repeat clause 5.2 and measure the sound pressure level of an additional slow whoop tone.	16 November 2011

TE264218-RF

Equipment		
No.	**Description**	**Receipt date**
16	SGRS100-AV audiovisual wireless wall sounder beacons	15 December 2010
8	SGRS100 wireless wall sounders	15 December 2010
8	SGRS100/H wireless wall sounders	15 December 2010
6	SGRBS100-AV audiovisual wireless base sounder beacons	7 December 2010
8	SGRBS100 wireless base sounder	7 December 2010

Second Submission

Equipment		
No.	**Description**	**Receipt date**
4	SGRBS100-AV audiovisual wireless base sounder beacons	08 August 2011
4	SGRBS100 wireless base sounder	08 August 2011

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

TEST RESULT **(SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)**	TE264218 928q01/02/03/04/06/07 The Argus Security range of wireless wall and base sounders and wall and base sounder beacons models SGRS100-AV, SGRS100, SGRS100/H, SGRBS100-AV and SGRBS100 met the requirements of tests taken from EN 54-3:20011 and LPCB/VdS Agreement Document AD6.24 as required by LPCB Test Schedule E122099/1.26 on the first submission, with the exception of model SGRBS100-AV which met the requirement of Clauses, 5.9 Damp heat steady state (endurance) and the extended radiated electromagnetic fields requirements from LPCB/VdS Agreement Document AD6.24 on the second submission and Clause 4.5.4 Access on the third submission. TE264218-RF The Argus Security S.r.l. products listed below, met the requirements of the applicable test defined in EN 54-25[1] and LPCB/VdS Agreement Document AD6.2[2] in accordance with LPCB Test Schedule E122099/1.2[3], as detailed in Section 7 of this report.	
PRODUCT APPLICATION GUIDELINE (END USE) **(CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC.**	**RSM-BS L20-SGRBS-7000** BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	**WEBSITE**	www.breglobal.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	**EMAIL**	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK		928q-(cl-6)

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	B V Thompson	**SIGNATURE**	
EMAIL / TEL	info@argussecurity.it	**FACTORY OFFICIAL SEAL**	ARGUS SECURITY Authorised by B.V Thompson on behalf of Argus Security Srl
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd. M McCullagh	**SIGNATURE**	
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	**CERTIFICATION BODY OFFICIAL SEAL**	BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.
NOTES: I Undertake that all data and information provided are genuine and accurate 928q-(cl-6)			

ATTACHMENTS:

- **COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)**