HOCHIKI
Your Safety, Our Technology

EC DECLARATION OF CONFORMANCE

This is to certify that in compliance BS EN 60598-2-22 Luminaires. Particular requirements for emergency Construction Products Regulation, this declaration applies to :

Declaration Number:	**KM653255-EL20**

Manufacture's Product:	Product Name	EL-20
	Intended Use	Intelligent Analogue Addressable Internally Illuminated Emergency Exit Sign

Produced by:	Hochiki Europe(UK) Limited Grosvenor Road Gillingham Business Park Gillingham Kent ME8 0SA

Authorised representative:	Mr Shane Bartlett Compliance Manager

System of Assessment:	System 1

Assessed by:	BSI Appliances (Notified Body 0086) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued following certificate of conformity: **KM 653255**

Declared Performance:	BS EN 60598-1	Luminaires. General requirements and tests
	BS EN 60598-2-2:2012	Luminaires. Particular requirements. Recessed luminaires
	BS EN 60598-2-22	Luminaires. Particular requirements. Luminaires for emergency lighting
	BS EN 61000-4-3	Electromagnetic compatibility (EMC). Testing and measurement techniques. Radiated, radio-frequency, electromagnetic field immunity test
	for the intended uses indicated above have been determined (1) See Annex A for the Essential Characteristics details (2) See Annex B for additional performance details	

HOCHIKI EUROPE (UK) LIMITED
Grosvenor Road, Gillingham Business Park,
Gillingham, Kent, ME8 0SA, United Kingdom
Telephone: +44 (0)1634 260133
Facsimile: +44 (0)1634 260132
e-mail (UK Sales): sales@hochikieurope.com
e-mail (Non UK Sales): export@hochikieurope.com
www.hochikieurope.com

Reg. Address: 11 Raven Wharf, Lafone Street,
Butlers Wharf, London SE1 2LR
Registered in England no. 2639909
VAT no. GB 573 8188 03

Your Safety, Our Technology

Annex A - Essential Characteristics

Essential characteristics	IEC 60598-2-22	Performance
Protection against electronic shock	22.12	Pass
Endurance & thermal test	22.13	Pass
Resistance to dust & moisture	22.14	Pass
Resistance to heat, fire & tracking	22.16	Pass
High temperature operation	22.19	Pass

Annex B – Additional Performance Details

- Rated 40V, IP20, supplied from EL-2 addressable control panel
- EL-BAT 450 (Rechargeable Lithium-polymer, 7.4 V, 450 mAh) Battery to be used
- Compatible with EL-REC20 recess adapter & YBN-R/3 mounting base
- Compatible with Firescape EL-20L (arrow to left), Firescape EL-20R (arrow to right) & Firescape EL-20D (arrow down) exit signs.

I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications.

Signed for and on behalf of the manufacturer:

Shane Bartlett
Compliance Manager
10th January 2018

CE	The performance of the above mentioned products are in conformity with the performance and essential characteristics declared within this certificate. This declaration of performance is issued under the sole responsibility of Hochiki Europe (UK) Ltd. This certificate will remain valid as long as the test methods and/or factory production control requirements included in harmonized standard, used to assess performance of the declared characteristics, do not change, and the product, and the manufacturing conditions are not modified significantly.

HOCHIKI EUROPE (UK) LIMITED
Grosvenor Road, Gillingham Business Park,
Gillingham, Kent, ME8 0SA, United Kingdom
Telephone: +44 (0)1634 260133
Facsimile: +44 (0)1634 260132
e-mail (UK Sales): sales@hochikieurope.com
e-mail (Non UK Sales): export@hochikieurope.com
www.hochikieurope.com

Reg. Address: 11 Raven Wharf, Lafone Street,
Butlers Wharf, London SE1 2LR
Registered in England no. 2639909
VAT no. GB 573 8188 03