
Random Hardware Reliability Certificate

Functional Safety of Safety-Related Programmable Electronic Systems

The **Hochiki Europe (UK) Ltd, CHQ-FTM and CHQ-FTM/DIN** (function is to monitor two 4-20mA current loop circuits with four threshold alarm settings, communicating to the Control Panel through the ESP Protocol) has been assessed and is considered capable for use in a low demand Safety Function up to (and including) SIL 2, with respect to random hardware failures and architectural constraints.

The following product variants are also covered under this certificate, with the product labels being the only difference:

- CHQ-FTM/SIL;
- CHQ-FTM/DIN/SIL;
- CHQ-FTM/DIN-RWY.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **Engineering Safety Consultants Ltd Report: E029_SV001 rev. 6;**
- **Renewal letter from Hochiki Europe (UK) Ltd, signed by Shane Bartlett, Compliance Manager Engineer, dated: 03/10/2022.**

The product was assessed against the following failure mode:

- **Failure to transmit any of the four alarms to the ESP Control Panel.**

The assessment was carried out to determine compliance with IEC 61508 (2010 Edition) with regards to:

- CHQ-FTM: SIL 2 with a HFT = via Route 1H;
- Architectural Constraint (Type A, SFF 60% - 90%).

Device	λ (/hr)	λ_{DU} (/hr)	λ_{DD} (/hr)	λ_s (/hr)	SFF (%)	Device Type	Estimated SIL Capability
CHQ-FTM	4.0E-07	8.7E-08	3.2E-07	0.0E+00	78	A	SIL 2

Note: The PFD or PFH of a complete SIF (inclusive of sensor, logic solver and final element subsystems) must be determined, considering any redundancy, Proof Test Interval (PTI), Proof Test Coverage (PTC), Mission Time and Mean Time To Restoration (MTTR) for all elements. Each subsystem should be verified to ensure compliance with the minimum HFT requirements.

IMPORTANT: It should be noted that this assessment does not include confirmation of the response time of the device. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.



Managing Director: Simon Burwood

Assessment Date: May 2015

Renewal Date: October 2022, valid to October 2024

Certificate: E029_CT001 rev. 8