IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	**IECEx BAS 12.0131X**	Page 1 of 4	Certificate history:
Status:	**Current**	Issue No: 3	Issue 2 (2018-11-28) Issue 1 (2018-01-30) Issue 0 (2013-03-22)
Date of Issue:	2023-08-17		

Applicant: **Hochiki Europe**
Grosvenor Road
Gillingham Business Park
Gillingham
Kent
ME8 0SA.
United Kingdom

Equipment: **Heat Detector Type DCD-1E-IS**

Optional accessory:

Type of Protection: **Intrinsic Safety**

Marking: **Ex ia IIC T5 Ga (-20°C ≤ Ta ≤ +55°C)**

Approved for issue on behalf of the IECEx Certification Body: **R S Sinclair**

Position: **Technical Manager**

Signature:
(for printed version)

Date:
(for printed version) 17/8/2023

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.

Certificate issued by:

SGS UK Limited
Rockhead Business Park
Staden Lane
Buxton, Derbyshire SK17 9RZ
United Kingdom

IECEx Certificate of Conformity

Certificate No.: **IECEx BAS 12.0131X**

Date of issue: 2023-08-17

Issue No: 3

Manufacturer: **Hochiki Europe**
Grosvenor Road
Gillingham Business Park
Gillingham
Kent
ME8 0SA.
United Kingdom

Manufacturing locations: **Hochiki Europe**
Grosvenor Road
Gillingham Business Park
Gillingham
Kent
ME8 0SA.
United Kingdom

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements.This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :
The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Edition:7.0 — Explosive atmospheres - Part 0: Equipment - General requirements

IEC 60079-11:2011 Edition:6.0 — Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:
A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

GB/BAS/ExTR12.0318/00
GB/SGS/ExTR23.0083/00
GB/BAS/ExTR18.0027/00
GB/BAS/ExTR18.0310/00

Quality Assessment Report:

GB/BAS/QAR13.0003/06

IECEx Certificate of Conformity

EQUIPMENT:
Equipment and systems covered by this Certificate are as follows:

The Heat Detectors Type DCD-1E-IS and Type DCD-1E-IS(WHT) are designed to detect temperature and the rate of rise of the temperature within a hazardous area and to provide an alarm indication on a locally mounted LED and also to provide an alarm indication to safe area mounted apparatus via a suitable interface.

The Heat Detector is mounted on Base Unit Types YBN-R/4IS or YBN-R/4IS(WHT) for installation within the hazardous area and comprises a printed circuit board encapsulated within a non-metallic housing, is populated with surface mounted components. When fitted to a Base Unit the enclosure provides a degree of protection of at least IP20 to the electronic circuit. The field wiring connections from the safe area apparatus, and to external simple apparatus such as switches and resistors, are made within the base unit.

This certificate covers the following variants:
DCD-1E-IS
DCD-1E-IS (WHT)

Input/output parameters

Supply Input Terminals 2 and 6 or Loop Output Terminals 1 and 5 and Remote Indicator Alarm Terminals 1 and 4

Ui = 30V	Ii = 200mA	Pi = 1W	Ci = 0	Li = 0
Uo = Ui	Io = Ii	Po = Pi	Ci = 0	Li = 0

Note :- Terminals 1 & 2 are directly interconnected only when the smoke detector is fitted to the Base Unit and Terminals 6 & 5 are directly interconnected within the Base Unit. All inputs / outputs are derived from a common source.

Terminal 3 may be used for terminating cable screens and has no electrical connection to the circuit.

SPECIFIC CONDITIONS OF USE: YES as shown below:
1) The Heat Detectors Type DCD-1E-IS and Type DCD-1E-IS(WHT) have a plastic enclosure which may present an electrostatic risk if rubbed or placed in a fast moving air flow.

IECEx Certificate of Conformity

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)
Variation 3.1

To permit label changes to add UKEX details and confirm that the equipment meets the requirements of IEC 60079-0:2017.

ExTR: **GB/SGS/ExTR23.0083/00** File Reference: **21/0129**