CERTIFICATE OF TEST

DATE OF ISSUE: **23 January 2007** CERTIFICATE NUMBER: **L312**

Environmental Test Services Ltd, Ladbroke Close, Woodley, Berks, RG5 4DX

ENVIRONMENTAL TEST SERVICES

Tel: 0118 927 2220 Fax: 0118 927 2120 E-Mail: ets@etsonline.co.uk

Registered in England No. 3110350

APPROVED SIGNATORY

J A Fennell
Laboratory Manager

Customer: Hochiki Europe (UK) Ltd
Grosvenor Road
Gilingham Business Park
Gillingham
Kent ME8 0SA

Order No: M068189

Description of Equipment Tested:

1 off CHQ-OEM
Type: CHQ-OEM (with CHQ Back Box)
Serial No: ETS RC1868/00/01 *
Manufactured by Hochiki Europe (UK) Ltd

* *Allocated by ETS in the absence of any other unique identification*

Tested to: **Dust Ingress Test** to
BS EN 60529:1991 paragraph 13.4
IP6X

Comments: The test item was received on 17 January 2007.
The test was performed on 18 January 2007.
The test was performed in accordance with the Test Specification.
The test duration was 8 hours.
No dust was found in the test item during a post test visual inspection performed by ETS.
All test records for the work detailed above are filed under Route Card No: 1868.
and will be retained by ETS for a minimum period of six years.
The test was performed using calibrated equipment traceable to National Standards.

Prepared by:
Neil Bond

CERTIFICATE OF TEST

DATE OF ISSUE: **19 February 2007** CERTIFICATE NUMBER: **U1111**

UKAS TESTING 1909

Environmental Test Services Ltd, Ladbroke Close, Woodley, Berks, RG5 4DX

ENVIRONMENTAL TEST SERVICES

Tel: 0118 927 2220 Fax: 0118 927 2120 E-Mail: ets@etsonline.co.uk

APPROVED SIGNATORY

J A Fennell
Laboratory Manager

Registered in England No. 3110350

Customer: Hochiki Europe (UK) Ltd
Grosvenor Road
Gilingham Business Park
Gillingham
Kent, ME8 0SA

Order No: M068248

Description of Equipment Tested:

1 off CHQ-OEM
Type: CHQ-OEM (with CHQ Back Box)
Serial No: ETS RC1868/02/02 *
Manufactured by Hochiki Europe (UK) Ltd

* *Allocated by ETS in the absence of any other unique identification*

Tested to:

Water Ingress Test to
BS EN 60529:1991 paragraph 14.2.5, IPX5 Water Jetting

Comments:

The test item was received 15 February 2007.
The test was performed on 16 February 2007.
The test was performed in accordance with the test specification.
The water temperature was recorded at 10.0°C prior to the test.
The UUT was preconditioned at 10.0°C overnight prior to the test.
No water was found in the test item during a post test visual inspection performed by ETS.
All test records for the work detailed above are filed under Route Card No. 1868/2 at ETS.

Prepared by:
N Bond