intertek
Total Quality. Assured.

Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address	:	**Hochiki Europe (UK) Ltd Grosvenor Road Gillingham Business Park Gillingham ME8 0SA Kent UNITED KINGDOM**
Product(s) Tested	:	**Analogue Multi-Sensors with SCI (Short Circuit Isolator)**
Ratings and principal characteristics	:	**17- 41 V d.c Operating Voltage -10°C to +50 °C Temperature Operating range Digital Communication using ESP.**
Model(s)	:	**ACC-E[WHT]-SCI and ACC-EN[SCI] Analogue Multi Sensors with SCI (Short Circuit Isolator) tested with YBN-R/3 Base (Ceiling Mount).**
Brand name	:	**Hochiki**
Relevant Standard(s)/Specification(s)	:	**BS EN 60529:1992+A2 2013 (Protection rating IP42). IP4X (Protection Against Access to Hazardous Parts). IPX2 (Protection Against Dripping Water).**
Verification Issuing Office Name & Address	:	**Intertek Cleeve Road Leatherhead, Surrey KT22 7SA United Kingdom**
Verification/Report Number(s)	:	**102927224LHD-001**

NOTE:- This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Signature:

Name: Allan Hurford
Position: Senior Engineer
Date: 6th March 2018