DNV·GL

TYPE APPROVAL CERTIFICATE

Certificate No:
TAA00001MF
Revision No:
2

This is to certify:

That the Fire Detector

with type designation(s)
SOC-E3NM, SOC-E3NM(WHT), SOC-E-ISM, SOC-E-ISM(WHT), DCD-CE3M, DCD-AE3M, DRD-EM, DCD-1E-IS, DCD-1E-IS(WHT), YBN-R/6M, YBN-R/6M(WHT), YBN-R/4IS,YBN-R/4IS(WHT), MBB-1, MBB-1(WHT), MBB-2, MBB-2(WHT)

Issued to
Hochiki Europe (UK) Ltd.
Gillingham, Kent, United Kingdom

is found to comply with
DNV GL rules for classification – Ships
IMO International Code for Fire Safety Systems (FSS Code) Chapter 9

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Temperature	**B**
Humidity	**B**
Vibration	**A**
EMC	**B**
Enclosure	**Required protection according to the Rules shall be provided upon installation on board.**

Issued at **Hamburg** on **2020-10-27**

This Certificate is valid until **2025-02-19**.
DNV GL local station: **Southampton**

Approval Engineer: **Heinz Scheffler**

for **DNV GL**
Digitally Signed By:
Papanuskas, Joannis

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **262.1-025949-3**
Certificate No: **TAA00001MF**
Revision No: **2**

Product description

Conventional Smoke Detector:
SOC-E3NM: Conventional Photoelectric Smoke Detector
SOC-E3NM (WHT): Conventional Photoelectric Smoke Detector (White)
SOC-E-ISM: Conventional Intrinsically Safe Smoke Detector
SOC-E-ISM(WHT): Conventional Intrinsically Safe Smoke Detector (White)

Conventional Heat Detector:
DCD-CE3M: Conventional high temperature heat detector
DCD-AE3M: Conventional heat detector
DCD-1E-IS: Intrinsically safe conventional rate of rise heat detector
DCD-1E-IS (WHT): Intrinsically safe conventional rate of rise heat detector (White)

Conventional Flame Detector:
DRD-EM: Conventional flame detector

Base:
YBN-R/6M: Standard mounting base
YBN-R/6M (WHT): Standard mounting base (White)
YBN-R/4IS: Intrinsically Safe Mounting Base
YBN-R/4IS(WHT): Intrinsically Safe Mounting Base (White)
MBB-1: Marine back box
MBB-1 (WHT): Marine back box (White)
MBB-2: Marine back box
MBB-2 (WHT): Marine back box (White)

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNVGL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNVGL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body

Type Approval documentation

Test Reports: TE-P103234, P103234-1001-SW, 103070255LHD-002, 103070255LHD-021, 103925944LHD-001i, 210418, TE 225596, P108884, TE94410, 103437212LHD-002a, 104050159LHD-041, 104050159LHD-001a, 104050159LHD-001b, 104050159LHD-001c, TE255345, TE255345a, P102507, 103437212LHD-021, TE296268, 104050159LHD-001d, TE-P115398-1000, SW-P115398-1000, 104165919LHD-021, 104165919LHD-001a
Documents:
General Assembly & Circuit Diagrams:
HA-01-592, HA-01-590, 7-0-000-3862-721, 7-0-000-0005-721, 7-0-000-3868-721, 7-0-000-0006-721, 2-1-0-051, 1217170-00, 7-0-000-1916-721, 7-0-000-1958-721, 1226350-00, 1226370-00, 1212330-00
Installation Instructions:
2-3-0-500, 2-3-0-345, 2-3-0-2853
Product Specification (Datasheets):
SOC-E3NM, DCD-AE3M, DCD-CE3M, DCD-1E-IS, DRD-EM, SOC-E-ISM

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, December 2019; EN 54-5 (2000) /A1(2002), EN 54-7 (2000)/A1(2002)/A2(2006), EN 54-10 (2002)/A1(2005), IEC 60092-504 (2016)

Marking of product

The products to be marked with:

- Model name
- Manufacturer name
- Serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE