Date : 11 April 2016

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE-P101540-1001 Iss 1	**CERTIFICATE NUMBER**	164q/25/26
DATE OF ISSUE	16 February 2016	**DATE OF ISSUE**	26 February 2016
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Hochiki Europe (UK) Ltd	**NAME OF THE BRAND**	Hochiki
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Grosvenor Road, Gillingham Business Park, Gillingham, Kent, ME8 0SA, United Kingdom	**MODEL / NO**	164q/25 CHQ-DSC2(SCI) 164q/25 CHQ-DSC2(HFP)-SCI 164q/26 CHQ-DSC2/DIN(SCI)
WEBSITE	www.hochikieurope.com	**LOGO ON THE PRODUCT**	HOCHIKI
TEL	+44 (0)1634 260133	**EMAIL**	info@hochikieurope.com

BRE GLOBAL LTD
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	164q/25 CHQ-DSC2(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator 164q/25 CHQ-DSC2(HFP)-SCI Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (HFP Brand) 164q/26 CHQ-DSC2/DIN-(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (DIN Rail Version)	
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-17: 2005 EN 54-18: 2005	
TEST DESCRIPTION	The object of this evaluation was to assess the performance of the Hochiki Europe (UK) Ltd CHQ-DSC2(SCI) and CHQ-DSC2/DIN(SCI), Intelligent Analogue Addressable Dual Sounder Controllers with Short Circuit Isolators for compliance with the requirements of EN 54-18:2005 and EN54-17:2005, LPCB/VdS AD EN 54-18 Rev 2, and LPCB/VdS AD EN 54-17 Rev 2.	
SPECIFICATION OF TEST SPECIMEN	**1.1 First submission**	

Equipment submitted for testing

No.	Description	Receipt date
8	CHQ-DSC2(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator	6/10/15
14	CHQ-DSC2/DIN(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (DIN rail version)	6/10/15
1	Kentec Series 8000 Fire Alarm Control Panel	Previously provided

1.2 Second submission

Equipment submitted for testing

No.	Description	Receipt date
8	CHQ-DSC2(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator	31/11/15

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

	14	CHQ-DSC2/DIN(SCI) Intelligent Analogue Addressable Dual Sounder Controller with Short Circuit Isolator (DIN rail version)	31/11/15	
	1	Kentec Series 8000 Fire Alarm Control Panel	Previously provided	
TEST RESULT (SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	The Hochiki Europe (UK) Ltd CHQ-DSC2(SCI) and CHQ-DSC2/DIN(SCI) Intelligent Analogue Addressable Dual Sounder Controllers with Short Circuit Isolators met the requirements of tests specified in LPCB Test Schedule P101540/1.2 taken from EN 54-18:2005 and EN-54-17:2005, LPCB/VdS AD EN 54-18 Rev 2 and LPCB/VdS AD EN 54-17 Rev 2 on the second submission.			
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC.	2-3-0-1730/ISS5/JAN16 and AP0127/ISS5/SEP15 BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK			

164q_25_26

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	**NAME OF TEST FACILITY**	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	**TEST FACILITY ADDRESS / REGION** (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	**WEBSITE**	www.breglobal.com
TEL	+44 (0)333 321 88 11	**TEL**	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	**EMAIL**	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	**ACCREDITED BY** (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	**AS PER** (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	**VALIDITY** (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	**REFERENCE NUMBER:** (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	**Hochiki Europe (UK) Ltd** 164q_25_26	

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	SHANE BARTLETT	SIGNATURE	
EMAIL / TEL	01634 266543	FACTORY OFFICIAL SEAL	HOCHIKI EUROPE (U.K.) LIMITED Grosvenor Road, Gillingham Business Park Gillingham, Kent ME8 0SA England
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd.	SIGNATURE	P. Halligan
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	CERTIFICATION BODY OFFICIAL SEAL	BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)

Hochiki Europe (UK) Ltd 164q_25_26