Date : 05 June 2017

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE-P105376-1001	**CERTIFICATE NUMBER**	117n-(cl-1)_01_02
DATE OF ISSUE	01 June 2017	**DATE OF ISSUE**	02 June 2017
DATE OF EXPIRY	N/A	**DATE OF EXPIRY**	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Hochiki Corporation	**NAME OF THE BRAND**	Hochiki
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	141-1 Maehara Ejiri Kakuda-Shi Miyagi 981-15 Japan	**MODEL / NO**	ACC-E(WHT)-SCI ACC-E(HFP)-SCI ACC-EN(SCI) ACC-EN(WHT)-SCI
WEBSITE	http://www.hochiki.co.jp/overseas/	**LOGO ON THE PRODUCT**	HOCHIKI
TEL	+81(0)42 795 129	**EMAIL**	hisato@hochiki.co.jp

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	ACC-E(WHT)-SCI - Intelligent Analogue Addressable Multi-Criteria Detector with Short Circuit Isolator ACC-E(HFP)-SCI - Intelligent Analogue Addressable Multi-Criteria Detector with Short Circuit Isolator ACC-EN(SCI) – Intelligent Analogue Addressable Multi-Criteria Detector with Short Circuit Isolator ACC-EN(WHT)-SCI – Intelligent Analogue Addressable Multi-Criteria Detector with Short Circuit Isolator	
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-5:2000 + A1:2002 EN 54-7:2000 + A1:2002 + A2:2006 EN 54-17:2002 CEA4021:2003	
TEST DESCRIPTION	The object of this evaluation was to assess the performance of the Hochiki Europe (UK) ACC-E(WHT)-SCI, ACC-EN(WHT)-SCI and ACC-EN(SCI) Multisensor Detectors to EN 54-17:2005, LPCB/VdS AD EN 54-17, EN 54-7: 2000+A1: 2002+A2: 2006, LPCB/VdS AD EN 54-7, EN 54-5: 2000+A1: 2002, LPCB/VdS AD EN 54-5 and CEA 4021:2003	
SPECIFICATION OF TEST SPECIMEN	Equipment No. / Description / Receipt date 20 / ACC-E (WHT)-SCI addressable analogue multisensor with short circuit isolator / 02/09/2016 20 / ACC-EN (WHT)-SCI addressable analogue multisensor with short circuit isolator / 02/09/2016 8 / YBV-R/4 mounting base / 02/09/2016	
TEST RESULT (SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	The Hochiki Europe (UK) ACC-E(WHT)-SCI, ACC-EN(WHT)-SCI and ACC-EN(SCI) Multisensor Detectors met the requirements of tests specified in Test Schedule P105376/1.1 taken from to EN 54-17:2005, LPCB/VdS AD EN 54-17, EN 54-7: 2000+A1: 2002+A2: 2006, LPCB/VdS AD EN 54-7, EN 54-5: 2000+A1: 2002, LPCB/VdS AD EN 54-5 and CEA 4021:2003 on the first submission. It should be noted that where applicable EMC testing was conducted to both EN 50130-4:1995 + A1:1998 + A2:2003 and EN 50130-4:2011.	

BRE GLOBAL LTD.
BUCKNALLS LANE
WATFORD
WD25 9XX, UK

PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT____/TO BE CONNECTED WITH____/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ETC.	2-3-0-246/ISS18/FEB17 AP0127/ISS6/FEB17 BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK	

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	NAME OF TEST FACILITY	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	TEST FACILITY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	www.breglobal.com	WEBSITE	www.breglobal.com
TEL	+44 (0)333 321 88 11	TEL	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bre.co.uk	EMAIL	BREGlobalEnquiries@bre.co.uk
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	AS PER (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2005
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	VALIDITY (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	REFERENCE NUMBER: (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LOSS PREVENTION CERTIFICATION BOARD LPCB BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK		117n-(cl-1)_01_02

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Richard Anderson	SIGNATURE	
EMAIL / TEL	randerson@hochikieurope.com 01634 266544	FACTORY OFFICIAL SEAL	HOCHIKI EUROPE (U.K.) LIMITED Grosvenor Road, Gillingham Business Park Gillingham, Kent ME8 0SA England
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd.	SIGNATURE	
EMAIL / TEL	BREGlobalEnquiries@bre.co.uk +44 (0)333 321 88 11	CERTIFICATION BODY OFFICIAL SEAL	BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.
NOTES: I Undertake that all data and information provided are genuine and accurate 117n-(cl-1)_01_02			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)