



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

System Designation:	SG-FK5112 FK-5-1-12 Fire Extinguishing System
Flow Calculation Software	SG Flow Calculation Software v4.00 (SG-FK-5112)
Design, Installation, Operation, Maintenance, Software, and Owner's Manuals:	SG-FK5112 FK-5-1-12 Fire Suppression System Design, Installation and Engineering Manual Part Number: SG-UL-FK-MNL, Rev 2

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Extinguishing Systems

Deluge Special Hazard Fire Systems Pte Ltd.
Block 3018 Bedok North Street 5 #02-17,
Singapore 468132
Singapore

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i>	
5600	August 2021

FM Approvals Listing Class: 5612

Original Approval Project Identification: PR464446
Subsequent Revisions: None

Approval Granted: 23 January 2023

To verify the availability of the Approved product, please refer to www.approvalguide.com


James E. Marquedant
VP, Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

23 January 2023

Date



Member of the FM Global Group